

QUESTIONS AND ANSWERS

- Q1.** Can I get a copy of the updated plan holders list? **Submitted bids will be available via a public records request after an award has been made.**
- Q2.** What is the estimated cost for this project? **Undetermined.**
- Q3.** Can I get a copy of any addenda that have been released to date? **All documents pertaining to the solicitation are available on Cal e-procure and the Court's website.**
- Q4.** Do we need to paint any window frames, window trim or anything around windows? **There are wooden framed and sashed windows in the historical building. They will need to be prepped and painted. The windows on the annex building are aluminum clad and will not need painting.**
- Q5.** Do we need to apply any Elastomeric coating? Exhibit A: Statement of Work calls for "Premium Exterior Grade Elastomeric or better appropriate for each building's construction (e.g. Dunn Edwards Evershield or better...)"Evershield is an ultra-premium exterior regular paint product by Dunn Edwards. Enduralastic 5 Exterior Elastomeric wall Coating is the actual elastomeric coating product by Dunn Edwards. Please, clarify if we need to use regular paint product or elastomeric coating product for the building walls. **Elastomeric coating with appropriate back-roll application.**
- Q6.** What product do we need to apply to the 1st floor concrete blocks of the Historical Courthouse? **No product application to the stone/concrete block. Cleaning and decalcification is requited during building prep for painting.**
- Q7.** Can you please clarify working days / hours for Historical Courthouse and Annex building? **Working hours for both buildings will be after hours 5:30 p.m.-5:30 a.m., and weekends.**